

PUBLIC NOTICE
#2020-20 Quicklime Supplier Bid
CITY OF LANCASTER, PA

The City of Lancaster, PA will receive sealed bids online for Quicklime supplier Bid for the Bureau of Wastewater until Thursday, December 10th, 2020 at 11:00AM at which time they shall be opened electronically and publicly posted on PennBid's website. All documents and solicitation details are available online at no cost on PennBid- www.PennBid.net.

Coarse granulated quicklime furnished and delivered to the Advanced Wastewater Treatment Plant (AWWTP) shall be high calcium, coarse granular quicklime containing an available calcium oxide content of at least 92%, total calcium oxide of at least 94% and a magnesium oxide content not greater than 1.5%. The product shall pass the following screen sizes: 3/8" sieve – 100% passing, 5/16" sieve – 97% passing, 1/4" sieve - 57% passing, No.4 sieve – 26% passing, and No.10 sieve -4% passing.

The AWWTP is located at 1220 New Danville Pike, Lancaster PA 17603. A 2,800 ft³ lime silo is located on-site and current operations of the AWWTP use approximately 600 tons of year of quicklime or 11.5 tons a week.

The City of Lancaster, PA reserves the right to reject any and all Bids and to accept the Bid, which is in the best interest of the City. The lowest responsible bidder need not be the bidder submitting the lowest dollar amount bid. The City may also consider the quality of the goods or services supplied, ease of repair, compatibility with other City equipment, responsiveness, past performance of the bidder and any other reasonable factors specified in the bid package.