

**CITY OF LANCASTER
BUREAU OF WATER
CHEMISTRY & MICROBIOLOGY LABORATORIES**



2021 DRINKING WATER ANALYSIS REPORT

TABLE OF CONTENTS

ANALYSIS	PAGE
INORGANIC	1
CHLORINE, TURBIDITY, MICROBIOLOGICAL TRIHALOMETHANES, HALOACETIC ACIDS	2
SECONDARY CONTAMINANTS, OTHER TESTS	3
VOLATILE ORGANIC CHEMICALS	4
SYNTHETIC ORGANIC CHEMICALS	5
ABBREVIATIONS	6

CITY OF LANCASTER
DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - PRIMARY CONTAMINANT LIST

INORGANIC

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP MCL</u>	
ANTIMONY	ND	mg/L	ND	mg/L	0.006	mg/L
ASBESTOS	ND	million fibers/L	ND	million fibers/L	7	million fibers/L
ARSENIC	ND	mg/L	ND	mg/L	0.01	mg/L
BARIIUM	0.053	mg/L	0.027	mg/L	2	mg/L
BERYLLIUM	ND	"	ND	"	0.004	mg/L
CADMIUM	0.0006	"	0.002	"	0.005	"
CHROMIUM	0.001	"	ND	"	0.1	"
COPPER	0.16	"	0.16	"	1.3	"
CYANIDE, Free	ND	"	ND	"	0.2	"
FLUORIDE	0.77	"	0.65	"	2.0	"
LEAD *	0.0057	"	0.0057	"	0.015	"
MERCURY	ND	"	ND	"	0.002	"
NICKEL	ND	"	ND	"	0.1	"
NITRATE	5.7	"	ND	"	10	"
NITRITE	ND	"	0.13	"	1	"
SELENIUM	ND	"	ND	"	0.05	"
THALLIUM	ND	"	ND	"	0.002	"

* Lead Levels from High Risk Homes in the Distribution System: 90th Percentile = 0.006 mg/L. Tested in 2019.

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - PRIMARY CONTAMINANT LIST

CHLORINE

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>	<u>OYSTER POINT RESERVOIR</u>	<u>DEP MCL</u>	
CHLORINE, Free Residual	1.26	1.14	4.0	mg/L

TURBIDITY

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>	<u>SUSQUEHANNA PLANT</u>	<u>PA DEP MCL</u>	
TURBIDITY, Combined Effluent	0.02 NTU	0.01 NTU	0.15	NTU

MICROBIOLOGICAL

	<u>RESULT</u>	<u>DEP TT</u>
TOTAL COLIFORM*	0.00%	<5% POSITIVES/MONTH

	<u>RESULT</u>	<u>PA DEP MCL</u>
ESCHERICHIA COLI*	0	0 POSITIVES/MONTH

TRIHALOMETHANES

	<u>RESULT</u>	<u>PA DEP MCL</u>
TRIHALOMETHANES, TOTAL * (Highest 12 Month Locational Running Annual Average)	61.2 µg/L	80 µg/L

HALOACETIC ACIDS

	<u>RESULT</u>	<u>PA DEP MCL</u>
HALOACETIC ACIDS, TOTAL * (Highest 12 Month Locational Running Annual Average)	36 µg/L	60 µg/L

* Results are from samples taken in the distribution system

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - SECONDARY CONTAMINANT LIST

SECONDARY

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP SMCL</u>	
ALUMINUM, Total	0.06	mg/L	0.05	mg/L	0.05	mg/L
CHLORIDE	31.8	"	20.3	"	250	"
COLOR	1	CU	0.3	CU	15	CU
IRON, Total	0.01	mg/L	0.02	mg/L	0.3	mg/L
MANGANESE, Total	0.026	"	0.017	"	0.05	"
pH	7.4	SU	7.4	SU	6.5-8.5	SU
SULFATE	44	mg/L	27	mg/L	250	mg/L

OTHER TESTS

	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP Range</u>	
ALKALINITY	158	mg/L	61	mg/L	NS	mg/L
HARDNESS, milligrams/liter	219	"	89	"	NS	"
HARDNESS, grains/gallon	13	GPG	5	GPG	NS	GPG
ORGANIC CARBON, Total	2.0	mg/L	1.7	mg/L	NS	mg/L
PHOSPHATE, Ortho	0.22	mg/L	0.22	mg/L	0.13-0.33	"
SPECIFIC CONDUCTANCE	597	µS/cm	283	µS/cm	NS	µS/cm

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - VOLATILE ORGANIC CHEMICAL LIST

VOLATILE ORGANIC CHEMICALS

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>PA DEP MCL</u>	
BENZENE	ND	mg/L	ND	mg/L	0.005	mg/L
CARBON TETRACHLORIDE	ND	"	ND	"	0.005	"
CHLOROBENZENE	ND	"	ND	"	0.1	"
1,2-DICHLOROBENZENE	ND	"	ND	"	0.6	"
1,4 - DICHLOROBENZENE	ND	"	ND	"	0.075	"
1,2-DICHLOROETHANE	ND	"	ND	"	0.005	"
1,1-DICHLOROETHENE	ND	"	ND	"	0.007	"
cis-1,2,-DICHLOROETHYLENE	ND	"	ND	"	0.07	"
trans-1,2,-DICHLOROETHENE	ND	"	ND	"	0.1	"
1,2-DICHLOROPROPANE	ND	"	ND	"	0.005	"
ETHYLBENZENE	ND	"	ND	"	0.7	"
METHYLENE CHLORIDE	ND	"	ND	"	0.005	"
STYRENE	ND	"	ND	"	0.1	"
TETRACHLOROETHENE	ND	"	ND	"	0.005	"
TOLUENE	ND	"	ND	"	1	"
1,2,4-TRICHLOROBENZENE	ND	"	ND	"	0.07	"
1,1,1-TRICHLOROETHANE	ND	"	ND	"	0.2	"
1,1,2-TRICHLOROETHANE	ND	"	ND	"	0.005	"
TRICHLOROETHENE	ND	"	ND	"	0.005	"
VINYL CHLORIDE	ND	"	ND	"	0.002	"
XYLENES (total)	ND	"	ND	"	10	"

CITY OF LANCASTER
DRINKING WATER ANALYSIS REPORT

PA DEPARTMENT OF ENVIRONMENTAL PROTECTION - SYNTHETIC ORGANIC CHEMICAL LIST

SYNTHETIC ORGANIC CHEMICALS

<u>ANALYSIS</u>	<u>CONESTOGA PLANT</u>		<u>SUSQUEHANNA PLANT</u>		<u>DEP MCL</u>	
ALACHLOR	ND	mg/L	ND	mg/L	0.002	mg/L
ALDICARB	ND	"	ND	"	0.003	"
ALDICARB SULFOXIDE	ND	"	ND	"	0.004	"
ALDICARB SULFONE	ND	"	ND	"	0.002	"
ATRAZINE	ND	"	ND	"	0.003	"
BENZO(a)PYRENE	ND	"	ND	"	0.0002	"
CARBARYL	ND	"	ND	"	NS	"
CARBOFURAN	ND	"	ND	"	0.04	"
CHLORDANE	ND	"	ND	"	0.002	"
DALAPON	ND	"	ND	"	0.2	"
DIBROMOCHLOROPROPANE	ND	"	ND	"	0.0002	"
BIS(2-ETHYLHEXYL)ADIPHATE	ND	"	ND	"	0.4	"
BIS(2-ETHYLHEXYL)PHTHALATE	ND	"	ND	"	0.006	"
DICAMBA	ND	"	ND	"	0.2	"
DINOSEB	ND	"	ND	"	0.007	"
DIQUAT	ND	"	ND	"	0.02	"
ENDOTHALL	ND	"	ND	"	0.1	"
ENDRIN	ND	"	ND	"	0.0002	"
ETHYLENE DIBROMIDE (EDB)	ND	"	ND	"	0.00005	"
GLYCOPHOSPHATE	ND	"	ND	"	0.7	"
HEPTACHLOR	ND	"	ND	"	0.0004	"
HEPTACHLOR EPOXIDE	ND	"	ND	"	0.0002	"
HEXACHLOROCYCLOPENTADIENE	ND	"	ND	"	0.05	"
3-HYDROXYCARBOFURAN	ND	"	ND	"	NS	"
LINDANE	ND	"	ND	"	0.0002	"
METHOMYL	ND	"	ND	"	NS	"
METHOXYCHLOR	ND	"	ND	"	0.04	"
METOLACHLOR	ND	"	ND	"	0.2	"
METRIBUXIN	ND	"	ND	"	0.2	"
OXAMYL (Vydate)	ND	"	ND	"	0.2	"
PENTACHLOROPHENOL	ND	"	ND	"	0.001	"
PICLORAM	ND	"	ND	"	0.5	"
PROPACHLOR	ND	"	ND	"	NS	"
SIMAZINE	ND	"	ND	"	0.004	"
2,4-D	ND	"	ND	"	0.07	"
2,4,5-TP (SILVEX)	ND	"	ND	"	0.05	"
2,3,7,8-TCDD (DIOXIN)	ND	"	ND	"	0.00000003	"

CITY OF LANCASTER

DRINKING WATER ANALYSIS REPORT

ABBREVIATIONS

°C - DEGREES CENTIGRADE

cm - CENTIMETER

CU - COLOR UNIT

HPC - HETEROTROPHIC PLATE COUNT

Mg/L - MILLIGRAMS/LITER

mL - MILLILITER

pCi/L - PICOCURIES/LITER

ND - NOT DETECTED

NS - NO STANDARD

NT - NO TEST

NTU - NEPHELOMETRIC TURBIDITY UNIT

TT - TREATMENT TECHNIQUE REQUIREMENT

WL - WORKING LEVEL

< - LESS THAN

MF/L - MILLION FIBERS PER LITER, LESS THAN 10 MICROMETERS LONG (ASBESTOS)

µS/cm - MICRO SEIMENS PER CENTIMETER

PA DEP - PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION

MCL - MAXIMUM CONTAMINANT LEVEL

SMCL - SECONDARY MAXIMUM CONTAMINANT LEVEL, Not Legally Enforceable